

DECLARATION OF PERFORMANCE



- | | |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------|
| 1. Unique identification | Close-in boiler sets |
| 2. Type | Close-in boiler sets PenTec 6 - 8 - 10 bar
Close-in boiler sets DUCO 6 - 8 - 10 bar |
| 3. Intended use | For domestic water only / max. 95 °C |
| 4. Name and address manufacturer | PenTec BV
Edisonweg 7 - 3442 AC Woerden
The Netherlands |
| 5. Name and address representative | - |
| 6. System of assessment and verification of constancy of performance | ISO 9001 |
| 7. Activity NOBO. + Identification nr. | KIWA 0620 |
| 8. European technical assessment | www.pentecbv.nl / www.duco.nl |
| 9. Declared performance | Expansion groups according to EN-1488
Pipe threads ISO EN-10226-1 (ISO 7/1)
ISO 228/1 (for connections)
tested: Air-tight at 6 - 10 bar |
| 10. The performance of these products is in conformity with the declared performance. This declaration of performance is issued under the sole responsibility of the manufacturer identified at point 4. | |

Signed for and on behalf of the manufacturer by:

Mr. A. A. (Ton) Katuin
Director

Woerden 01-01-2017

